NARRABRI SEWAGE TREATMENT PLANT - MONTHLY POLLUTION MONITORING SUMMARY -April 2021

Environment Protection Licence No. 200
Anniversary date: 01 August
Version date: 13-Sep 2013

>219-1000ML Discharge (Small Plant)

Licensee Narrabri Shire Council
PO BOX 261
Narrabri NSW 2390

QUALITY/PERFORMANCE MONITORING

EPA ID. No. 1 DISCHARGE TO WATERS EFFLUENT QUALITY & VOLUME MONITORING	Site Description - Effluent Discharge Pipeline - to Narrabri Creek -POINT 1 -NOT IN USE**															
				Monthly Summary												
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	50%ile Limit	50%ile Actual	90%ile Limit	90%ile Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	20.0	N/A	30.0	N/A	N/A
Oil and Grease	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.0	N/A	N/A	N/A	N/A
pH	pH	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.5-8.5	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	45.0	N/A	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	CFU/100ml	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrate +Nitrite (oxidised nitrogen)	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total dissolved solids	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total kjeldahl Nitrogen	milligrams per litre	Each overflow event	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

**No samples were collected as no discharge occurred during the month

EPA ID. No. 2 DISCHARGE TO UTILISATION AREA EFFLUENT QUALITY & VOLUME MONITORING	Site Description - Inlet to Pipeline - to transfer effluent to effluent irrigation federation farm - POINT 2												
				Monthly Summary									
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Minimum	Mean Value	Median Value	Maximum	Actual	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Monthly	1	-	-	-	-	25	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	CFU per 100 mL	Monthly	1	-	-	-	-	440	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Monthly	1	-	-	-	-	16	N/A	N/A	N/A	N/A	N/A
Calcium	milligrams per litre	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chloride	milligrams per litre	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Conductivity	Micro siemens per centimetre	Monthly	1	-	-	-	-	1070	N/A	N/A	N/A	N/A	N/A
Magnesium	milligrams per litre	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	-	-	-	-	5.51	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	-	-	-	-	0.25	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	-	-	-	-	9	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	-	-	-	-	<5	N/A	N/A	N/A	N/A	N/A
pH	milligrams per litre	Monthly	1	-	-	-	-	8.5	N/A	N/A	N/A	N/A	N/A
Phosphorus	milligrams per litre	Monthly	1	-	-	-	-	4.3	N/A	N/A	N/A	N/A	N/A
Sodium	milligrams per litre	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Sodium Adsorption Ratio	Sodium adsorption ratio	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total dissolved solids	milligrams per litre	Quarterly	1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl as Nitrogen	milligrams per litre	Monthly	1	-	-	-	-	3.5	N/A	N/A	N/A	N/A	N/A

VOLUME MONITORING

EPA ID. No. 3 INFLUENT VOLUME MONITORING	Site Description - Inlet to Sewage Treatment Works - POINT 3											
				Monthly Summary								
Unit of measurement	Sampling frequency	Method	No. of times measured during the month for licence reporting	Minimum	Mean Value	Median Value	Maximum Value	Actual Value	3DGM Limit	3DGM Actual	100%ile Limit	Volume limit	Within Limits
Kilolitres per day	Continuous	In line instrument	30	1085	1534.433333	-	2032	46033	-	-	-	-	N/A

DEPTH MONITORING

EPA Id. No. 4 DEPTH MONITORING (LEVEL OF EFFLUENT IN STORMWATER BALANCING POND)	Site Description - Stormwater Detention Basin -POINT 4										
				Monthly Summary							
Location / units	Sampling Frequency	Method	No. of times measured	Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Storm pond level (m)	Daily	Inspection	30	1.2	1.286666667	-	1.4	-	-	-	-	N/A
Effluent pond level (m)	Daily	Inspection	30	1.2	1.34	-	1.4	-	-	-	-	N/A

Note: For pollutants with less than four samples measured during the monthly period see below for interpretation of summary tables:
One required sample for licence reporting: Min, Mean, Median and Max values are all the exact data point
Two required samples for licence reporting: Min and Max values are the two exact data points
Three required samples for licence reporting: Min, Median and Max values are the three exact data points

VOLUME MONITORING

Monthly Summary									
Monitoring Point	Unit of Measurement	Sampling Frequency	No. of times measured during the month	Minimum	Mean	Maximum	Actual total Monthly Volume	Volume Limit L/s	Within Limits
Point 1 - Wet Weather bypass to River (NOT IN USE)	megalitres per day	Daily (overflow only)	-	-	-	-	-	20	N/A
Point 2 - Effluent Irrigation to Federation Farm	kL per day	Daily	30	0	1717.666667	5,056	51,530	N/A	N/A

FLOW MONITORING

Monthly Summary									
Flow Range	Unit of Measurement	Sampling Frequency	No. of times measured during the month	Minimum	Mean	Maximum	Total Monthly Flow L/S	Flow Limits L/s	Within Limits
Point 1 - Wet Weather bypass to River (NOT IN USE)	L/s & Kilolitres per day	Each overflow event (via calculation)	-	-	-	-	-	250	-
Point 2 - Effluent Irrigation to Federation Farm	L/s & Kilolitres per day	Daily (Continuous) -In line instrument	30	0	1717.666667	5056	0.0198	80	YES
Bypass to the Storm Pond	L/s	Daily	-	-	-	-	-	80-250	N/A

ASSESSABLE POLLUTANT - pollutant discharge during reporting period

Yearly (TO BE ASSESSED AT THE END OF THE YEARLY PERIOD)									
ASSESSABLE POLLUTANT	Load Limit (kg) Per Year	Sampling Frequency	No. of times measured during the month		Minimum	Mean	Maximum	Flow Limit	Within Limits
BOD (Enclosed water)	14540	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrogen (total) (enclosed water)	29080	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Oil and Grease (enclosed water)	7270	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Phosphorus (total) (enclosed water)	7270	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total suspended solids (enclosed water)	37620	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A