

HB.147-96.6

DEVELOPMENT CONTROL PLAN – WATER SUPPLY TO BUILDINGS

1. OBJECTIVE

To ensure that there is an adequate supply of water for domestic purposes; and, to ensure that there is adequate provision to prevent contamination of Council's water supply.

2. POLICY:

- 2.1 Residential buildings erected on land not connected to Council's Water Supply shall have a minimum 45,000 litres of rainwater storage tank for domestic use. *(45,000 litres of above ground water storage, being delivered to the household at a minimum 0.15 litres per second, with an annual sustainable supply capacity of 800 kilolitres or greater.)*
- 2.2 Any fitting or appliance identified as a possible source of contamination in Table 4.2 of Part 1 – AS 3500 that is connected to Council's water supply or a private supply used for human consumption, shall be fitted with a back flow prevention device as specified in AS 3500 National Plumbing and Drainage Code.